



CERTIFICATE OF COMPLIANCE

FOR

**Genesis Manufacturing, Inc.
Fortville, IN 46040**

Ante Room

The above referenced clean zone has successfully passed the minimum requirements for an ISO Class 8 clean zone per the requirements of ISO Standards 14644-1:1999 and 14644-2:2000 for particle count testing of Cleanrooms and associated controlled environments.

This clean zone was tested in the Operational occupancy state at 0.5 micrometers and larger particle sizes. Testing was performed as outlined in ISO Standards 14644-1:1999, 14644-2:2000 and 14644-3:2005. The classification is applicable to the above clean zone designated in the report prepared April 2010.

Date of Certification: April 01, 2010

Due for Retest: April-2011

Certified By: Josh Kinser

Reviewed: CENV20105107/Jeff McCabe