


Lewis Testing Services, Inc.
P.O. Box 39109
Indianapolis, IN 46239

CLEAN ROOM PERFORMANCE CERTIFICATION

This is to certify that the clean room named below and its associated clean air handling system has been tested in accordance with the protocol and specification set forth in ISO 14644-1. Test details of this certification are outlined in the report.

Genesis Plastics Welding
720 East Broadway Street
Fortville, IN

Clean Room:	Clean Room 1	Design Type:	Vertical Flow
Test Report Number:	270-1222	Standard Used:	ISO 14644-1:2015
Date Tested:	July 27, 2020	Recertification Due:	January 2021
Particle Count Cleanliness Class:	ISO Class 7 for 0.5 µm particle size	Operational (Dynamic)	
Air Changes per hour Test:	PASS	Pressurization Test:	PASS



Tested/Certified by
Brian Hoffman

Clean Room Technician
Title



Reviewed/Approved by
Nathan Dinges

President
Title

Any questions regarding this certification should be directed to:

Lewis Testing Services, Inc.
P.O. Box 39109
Indianapolis, IN 46239
Tel: (317) 351-4160 Fax: (317) 351-4165




Lewis Testing Services, Inc.
P.O. Box 39109
Indianapolis, IN 46239

CLEAN ROOM PERFORMANCE CERTIFICATION

This is to certify that the clean room named below and its associated clean air handling system has been tested in accordance with the protocol and specification set forth in ISO 14644-1. Test details of this certification are outlined in the report.

Genesis Plastics Welding
720 East Broadway Street
Fortville, IN

Clean Room:	Clean Room 3	Design Type:	Vertical Flow
Test Report Number:	270-1222	Standard Used:	ISO 14644-1:2015
Date Tested:	July 27, 2020	Recertification Due:	January 2021
Particle Count Cleanliness Class:	ISO Class 7 for 0.5 μm particle size	Operational (Dynamic)	
Air Changes per hour Test:	PASS	Pressurization Test:	PASS



Tested/Certified by
Brian Hoffman

Clean Room Technician
Title



Reviewed/Approved by
Nathan Dinges

President
Title

Any questions regarding this certification should be directed to:

Lewis Testing Services, Inc.
P.O. Box 39109
Indianapolis, IN 46239
Tel: (317) 351-4160 Fax: (317) 351-4165



Lewis Testing Services, Inc.
P.O. Box 39109
Indianapolis, IN 46239

CLEAN ROOM PERFORMANCE CERTIFICATION

This is to certify that the clean room named below and its associated clean air handling system has been tested in accordance with the protocol and specification set forth in ISO 14644-1. Test details of this certification are outlined in the report.

Genesis Plastics Welding
720 East Broadway Street
Fortville, IN

Clean Room:	Gowning Area	Design Type:	Vertical Flow
Test Report Number:	270-1222	Standard Used:	ISO 14644-1:2015
Date Tested:	July 27, 2020	Recertification Due:	January 2021
Particle Count Cleanliness Class:	ISO Class 7 for 0.5 μm particle size	Operational (Dynamic)	
Air Changes per hour Test:	PASS	Pressurization Test:	PASS

Tested/Certified by
Brian Hoffman

Reviewed/Approved by
Nathan Dinges

Clean Room Technician

Title

President

Title

Any questions regarding this certification should be directed to:

Lewis Testing Services, Inc.
P.O. Box 39109
Indianapolis, IN 46239
Tel: (317) 351-4160 Fax: (317) 351-4165